

C&I Energy storage EMU300 Detailed Introduction

Detailed Introduction

Version: V5.3

Document ID: Feisjy-EMS-EMU300-2026

Shenzhen Feisijieyue Technology Co., Ltd.

February 2026

Catalog

1. EMS TECHNICAL REQUIREMENT	1ST
1.1. GENERAL REQUIREMENT	1ST
1.2. RUN RULES	1ST
1.3. DATA ACQUISITION, DISPLAY AND STORAGE	2ND
1.4. SYSTEM ARCHITECTURE DESIGN	3RD
2. RUNTIME ENVIRONMENT	4TH
2.1. HARDWARE EQUIPMENT	4TH
2.2. ENVIRONMENTAL REQUIREMENTS	4TH
2.3. INSTALLATION METHODS	4TH
2.4. SUPPORT SOFTWARE	4TH
3. FUNCTIONAL REQUIREMENT	6TH
3.1. ENERGY STORAGE FUNCTION	6TH
3.1.1. Overview of the power station	6th
3.1.2. PCS	6th
3.1.3. BMS	7th
3.1.4. Battery	8th
3.1.5. Auxiliary control monitoring	9th
3.1.6. Alarm analysis	10th
3.1.7. Alarm configuration	10th
3.1.8. Electricity tariff configuration	11th
3.1.9. Data analysis	13th

3.1.10. Operational Strategy	14th
3.1.11. Device management	15th
3.1.12. System settings	17th
3.1.13. Meter reading	19th
3.1.14. Meter data	19th
3.2. DATA ACQUISITION FUNCTION	20TH
3.2.1. Home page	20th
3.2.2. Southbound configuration	21st
3.2.3. Model configuration	23rd
3.2.4. Operation configuration	24th
3.2.5. Subroutine configuration	25th
3.2.6. Northbound configuration	26th
3.2.7. Alarm rules	27th
3.2.8. Configuration management	28th
3.2.9. System configuration	29th
3.2.10. System management	31st
3.2.11. System debugging	33rd
3.2.12. Rule engine	34th
4. EMU HARDWARE REQUIREMENTS	35TH
4.1. PRODUCT FEATURES	35TH
4.2. PRODUCT VIEW	36TH
4.3. EMU PARAMETER	37TH

4.3.1. Hardware parameters	37th
4.4. SCREEN OPTIONAL	38TH

1. EMS Technical Requirement

The Energy Management System (EMS) for industrial and commercial energy storage primarily consists of modules including Power Conversion System (PCS), Battery Management System (BMS), battery cells, equipment monitoring, report analysis, auxiliary control, centralized control, load tracking, alarm history, and configuration center.

1.1. General Requirement

The equipment configuration and functional requirements of the Energy Storage Management System (EMS) are designed for unattended operation in industrial and commercial energy storage power stations.

The EMS monitoring system for industrial and commercial energy storage power stations covers data from batteries, power conversion systems (PCS), transformers, air conditioning units, fire protection systems, and switchgear. Battery data includes individual cells, battery clusters, and battery stacks. PCS information encompasses operational status, voltage, current, and active power.

It has the following main features:

- (1) The system provides real-time monitoring of all station equipment, tracking operational status, recording data, and supporting historical data queries.
- (2) It supports energy control strategies, including timed and power-controlled charging/discharging, to meet peak-valley arbitrage and load leveling requirements.
- (3) Through coordinated control of the battery management system (BMS), it collects BMS alarm information and supports controlling the power reduction or shutdown of the power control system (PCS) to ensure optimal battery operation.
- (4) It supports external communication and cloud transmission, accessible via a local switch or built-in 4G/5G module. The data features local caching and a resume capability.
- (5) Data can be viewed in the cloud and on mobile devices.

1.2. Run Rules

General Principles of Energy Storage System Operation

The control objectives are to maximize the peak shaving and valley filling benefits, not to feed back to the grid, and not to overload the transformer during charging.

During off-peak hours at night and daytime low-load periods, the Energy Management System (EMS) controls the Power Conversion System (PCS) to charge energy storage based on battery State of Charge (SOC), while discharging during peak electricity hours.

- (1) When the load power is less than or equal to the maximum discharge power of the energy storage system, the EMS controls the discharge power of the energy storage PCS to be $\leq$ the load power.
- (2) When the load power exceeds the maximum discharge capacity of the energy storage system, the EMS controls the PCS to discharge at its maximum capacity.
- (3) During load mutation, the EMS system monitors the load power in real time and controls the charging/discharging power of the energy storage PCS, ensuring that the discharged energy from the storage does not feed back into the grid.

Specific application scenarios include the following:

- 1) Peak shaving and valley filling strategy: control the battery discharge during the peak load phase (electricity price peak) to control the load at a reasonable level. When the load is low, choose the appropriate time period (electricity price valley section) to charge in the appropriate way.
- 2) Demand control strategy: systematic monitoring of grid-connected points to absorb grid electricity; When the grid-connected point absorbs the power consumption of the grid, it increases; exceeding a certain threshold; The energy storage system automatically increases the output; Ensure that the total power of the grid-connected point is less than the set threshold.
- 3) Anti-countercurrent control strategy: system monitoring of grid-connected points absorbing electricity consumption from the grid; When the grid-connected point absorbs less electricity from the grid; The energy storage system automatically reduces the output; Ensure that the energy storage system does not send power backwards to the grid; When the system has a reverse power transmission phenomenon; The system should immediately control the corresponding relay at the grid-connected point to trip.

1.3. Data acquisition, display and storage

- (1) The system provides real-time monitoring of operational status and fault alerts across all devices, including: PCS (Power Control System) data (power, voltage, current, etc.) and status; BMS (Battery Management System) data (cell voltage, temperature, SOC, etc.) and status; energy meter data (forward/reverse active power, reactive power, power factor, voltage, current, etc.); and status information for system access control, water intrusion detection, switches, air conditioning, and fire safety systems (transmitted via BMS or directly connected through dry contacts).
- (2) The query displays the operation records of each device, showing the operation data curves and working status curves of the devices in the database.
- (3) The statistics of charging and discharging quantity can be queried by year, month and day.
- (4) Store for ≥ 90 days, including fault status information, with data collection completed within 3 seconds per cycle.

1.4. System Architecture Design

Scenario architecture diagram:

Electricity/New Energy: This technology can be applied to power equipment monitoring, solar power generation systems, wind power generation systems, photovoltaic energy storage charging stations, and microgrid scenarios, enabling remote monitoring and control of energy equipment to enhance energy utilization efficiency.




Figure 1-1 Architecture Diagram




Figure 1-2 Functional Composition Diagram

2. Runtime Environment

2.1. Hardware equipment

Powered by an EMU device: 4-core processor, 512MB RAM, 32GB storage, with RK3308 recommended for domestic production



2.2. Environmental requirements

- Altitude: <4000m.
- Maximum ambient temperature (indoor or outdoor): 55°C;
- Minimum temperature: -25°C; Maximum daily temperature difference: 25°C;
- Maximum relative humidity: daily average: 95%; monthly average: 90%;
- Operating temperature: -30°C to +55°C;
- Seismic resistance: Seismic fortification intensity: 9 (0.2g)

2.3. Installation methods

Pre-installed in containers or outdoor cabinets, with standard rack-mounted cabinets at 1U height.

2.4. Support software

Database SQLite, TDengine, Redis

Developing languages: Vue, JavaScript, and Go

EMQX and Nanomq middleware

3. Functional Requirement

3.1. Energy storage function

3.1.1. Overview of the power station

The power station overview displays information on the power station, including operational power, equipment details, power generation, and revenue. Equipment details include PCS, BMS, and auxiliary control information. Revenue statistics are displayed on a weekly, monthly, and yearly basis, allowing users to switch between these views. The central part of the page shows configuration information and corresponding equipment location details, as shown in Figure 3-1.




Figure 3- 1 Project Overview

3.1.2. PCS

The module displays basic information such as PCS information, equipment status, manufacturer, equipment model, battery cluster, number of batteries, battery specifications, and rated power. It shows active and reactive power. On the DC side, it displays total voltage and total current. For AC measurement, it shows voltage, current, active and reactive power, apparent power, and frequency. The left side of the module displays real-time and historical alarm information for the PCS, as shown in Figure 3-2.




Figure 3-2 PCS

3.1.3. BMS

The BMS Battery Manager module displays the status of battery clusters, battery health, and remaining power. It also shows cluster extreme values, including the highest and lowest voltages, temperatures, SOC, and serial numbers. In the lower left corner, it displays cluster power information, including statistics on charge and discharge. Users can click to switch between daily, weekly, and monthly statistics. In the lower right corner, it displays historical alarm information, such as low battery voltage and excessive current discharge. The middle section shows the real-time status of the equipment in a configuration format, as illustrated in Figures 3-3.



Figure 3-3 BMS Main Interface

3.1.4. Battery

The battery page mainly displays the cell information. Users can view the real-time voltage, temperature, SOC and SOH measurement point information, as shown in Figure 3-4 and Figure 3-5.



Figure 3- 4 Battery Data



Figure 3- 5 Historical data

3.1.5. Auxiliary control monitoring

The auxiliary control mainly displays and detects auxiliary control equipment, such as air conditioning, liquid cooling units, comprehensive protectors and other equipment. It also checks measurement points, alarm records and other information, as shown in Figure 3-6.



Figure 3- 6 Auxiliary Control Information

3.1.6. Alarm analysis

The alarm analysis module displays all alarm records of the project, categorizing them by level: critical, major, severe, and urgent. It also provides detailed information on each alarm, including the device name, alarm level, event description, occurrence time, creation and recovery times, and time status. The module allows users to manually confirm alarm records, filter records based on specific conditions, and view records in a paginated manner, as shown in Figure 3-7.



Figure 3- 7 Alarm History

3.1.7. Alarm configuration

The alarm configuration adds rules to determine whether the point condition meets the trigger condition and generates an alarm record, as shown in Figure 3-8.




Figure 3- 8 Alarm Configuration

3.1.8. Electricity tariff configuration

3.1.8.1. Electricity price setting

The price setting is used to set and manage the price information of different months, including time template and price template. The price situation in different periods is displayed intuitively in a graphical way, as shown in Figure 3-9.




Figure 3- 9 Electricity Price Setting

3.1.8.2. Time template

The time template facilitates the creation, editing and management of electricity price periods according to the type of electricity price. As shown in Figure 3-10.




Figure 3- 10 Time template

3.1.8.3. Electricity price template

The electricity price template creates, edits and manages specific electricity price information according to the type of electricity price. As shown in Figure 3-11.




Figure 3- 11 Electricity Price Template

3.1.8.4. Type of electricity price

Customize and manage the name and color of the electricity price type, which is convenient to display in the electricity price setting, time template and electricity price template. As shown in Figure 3-12.




Figure 3- 12 Type of Electricity Price

3.1.9. Data analysis

3.1.9.1. statement analysis

Users can view the charging current and discharge current information of day and month. Charging is divided into forward active total, peak, peak, flat and valley energy, and discharge is reverse active total, peak, peak, flat and valley energy, as shown in Figure 3-13.

Overview of the p

PCS

BMS

Battery cells

Auxiliary control n

Alarm analysis

Alarm configuratic

Electricity price con

Data analysis^

Report analysis

Load tracking

Run the policy^

Device managem

Meter reading confi

System Settings

Report

日电能表

2026-02-01 to 2026-02-26

Inquiries

Date *	pointed		peak		Flat		valley		Revenue (yuan)
	Charging volum	Discharge volu	Charging volum	Discharge volu	Charging volum	Discharge volu	Charging volum	Discharge volu	
	e	me	e	me	e	me	e	me	
2026-02-10	9.00	285.00	131.00	10588.00	1149.00	7073.00	19451.00	0.00	0.00
2026-02-09	9.00	285.00	128.00	10335.00	1146.00	6990.00	19065.00	0.00	0.00
2026-02-04	9.00	285.00	115.00	9066.00	1134.00	6271.00	16796.00	0.00	0.00
2026-02-03	9.00	285.00	113.00	8815.00	1131.00	6268.00	16507.00	0.00	0.00
2026-02-08	9.00	285.00	125.00	10082.00	1144.00	6880.00	18651.00	0.00	0.00
2026-02-07	9.00	285.00	123.00	9829.00	1141.00	6841.00	18316.00	0.00	0.00
2026-02-06	9.00	285.00	120.00	9574.00	1138.00	6588.00	17737.00	0.00	0.00
2026-02-05	9.00	285.00	118.00	9320.00	1136.00	6512.00	17380.00	0.00	0.00
2026-02-02	-64.00	0.00	4.00	505.00	-153.00	-200.00	505.00	-52.00	0.00
2026-02-01	73.00	285.00	106.00	8060.00	1281.00	6465.00	15713.00	52.00	0.00

Figure 3- 13 Statement Analysis

3.1.9.2. Load following

Provide detailed monitoring and analysis of energy load in the form of charts to help users understand energy consumption patterns, optimize energy use strategies, and improve energy efficiency. See Figure 3-14.




Figure 3- 14 Load following

3.1.10. Operational Strategy

3.1.10.1. Strategy management

Strategy configuration shows the usage scenarios and functions of various strategy configurations in the system by combining graphics and text, as shown in Figure 3-15.





Figure 3- 15 Strategy Management

3.1.10.2. Strategy history

The history is issued to record and query the historical records of policy issuance, so that users can track the policy issuance and know whether the policy has been successfully issued to the specified device. As shown in Figure 3-16.



Strategy Name	Execution Type	Execution Content	Execution Time	Execution Result
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:22:04	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:54	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:45	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:34	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:24	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:14	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:21:04	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:54	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:45	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:35	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:24	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:14	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:20:04	Failed
Grid connection standby	Timed tasks	Grid-connected standby processing exception: PCS connection and off-grid status query...	2026-02-26 09:19:54	Failed

Total 1761831 1 2 3 4 5 6 ... 8892 Go to 1

Figure 3- 16 Strategy History

3.1.11. Device management

3.1.11.1. Device analysis

By filtering device, , the device information status can be detected in real time, as shown in Figure 3-17.




Figure 3- 17 Device Analysis

3.1.11.2. Device ledger

The device ledger is used to display the basic information of the device, and users can view, edit, and manage the point operations, as shown in Figure 3-18.



Device Code	Device Name	Device Type	Device Group	Device Model	Manufacturer	Operation
1	PCS	PCS object model	--	--	--	Managed Points Edit Delete
2	BMS	BMS object model	--	--	--	Managed Points Edit Delete
3	Air conditioning	制冷	--	--	--	Managed Points Edit Delete
4	Fire protection	Fire protection	--	--	--	Managed Points Edit Delete
5	Anti-countercurrent meter 1	Anti-countercurrent meter	--	--	--	Managed Points Edit Delete
6	Anti-countercurrent meter 2	Anti-countercurrent meter	--	--	--	Managed Points Edit Delete
7	Energy meter	Energy storage meter	--	--	--	Managed Points Edit Delete
99	Energy storage system equipm	Energy storage system m...	--	--	--	Managed Points Edit Delete

Figure 3- 18 Device Ledger

3.1.11.3. Device model

Manage the unique identity of the device model, the unique identity of the point, and the electricity price configuration, as shown in Figure 3-19.



Model Code	Model Name	Unique Identifier	Operation
1	PCS object model	pcs	Managed Points Edit Delete
2	BMS object model	bms	Managed Points Edit Delete
3	Anti-countercurrent meter	ac_meter	Managed Points Edit Delete
4	制冷	air_conditioner	Managed Points Edit Delete
5	Fire protection	fire_fighting	Managed Points Edit Delete
6	Energy storage meter	em_meter	Managed Points Edit Delete
7	Dehumidifier	dehumidifier	Managed Points Edit Delete
8	Load meter	load_meter	Managed Points Edit Delete
99	Energy storage system model	energy_system	Managed Points Edit Delete

Figure 3- 19 Device Model

3.1.11.4. Real-time control

It supports remote control and remote adjustment of the control device, and issues instructions to make the device effective, as shown in Figure 3-20.




Figure 3- 20 Real-time Control

3.1.11.5. Control history

The control history records the operation of issuing point information in real-time control, which is convenient for user to observe whether the delivery operation takes effect, as shown in Figure 3-21.




Figure 3- 21 Control History

3.1.12. System settings

3.1.12.1. User management

Manage user basic information, login name, mobile phone number, role assignment, and password reset, as shown in Figure 3-22.




Figure 3- 22 User Management

3.1.12.2. Audit logs

The audit log records important information such as the IP address and time when users log in to the platform, tracks and audits user operation behaviors, and ensures platfor security and compliance. As shown in Figure 3-23.




Login Name	User	Ip	Content	Time
root	Super admin	113.13.119.98	Log in to the energy storage platform	2025-01-14 13:41:25
root	Super admin	183.237.184.244	Log in to the energy storage platform	2025-01-05 10:13:55
root	Super admin	183.237.184.244	Log in to the energy storage platform	2025-12-30 14:32:59
root	Super admin	183.237.184.244	Log in to the energy storage platform	2025-12-30 14:22:32
root	Super admin	127.0.0.1	Log in to the energy storage platform	2025-12-10 03:43:07
root	Super admin	127.0.0.1	Log in to the energy storage platform	2025-12-10 03:29:23
root	Super admin	127.0.0.1	Log in to the energy storage platform	2025-11-08 08:12:50
root	Super admin	116.253.122.25	Log in to the energy storage platform	2025-10-29 20:52:13
root	Super admin	124.226.46.205	Log in to the energy storage platform	2025-10-21 10:01:36
root	Super admin	124.226.46.205	Log in to the energy storage platform	2025-10-21 09:59:29
root	Super admin	124.226.46.205	Log in to the energy storage platform	2025-10-21 09:57:25
root	Super admin	127.0.0.1	Log in to the energy storage platform	2025-10-20 11:48:55
root	Super admin	180.141.151.75	Log in to the energy storage platform	2025-10-17 09:42:03
root	Super admin	180.141.151.75	Log in to the energy storage platform	2025-10-17 09:39:05
root	Super admin	180.141.151.75	Log in to the energy storage platform	2025-10-16 15:22:54
root	Super admin	127.0.0.1	Log in to the energy storage platform	2025-10-16 15:18:15

Figure 3-23 Audit Logs

3.1.12.2.1. Power station information

This module mainly displays the basic information of the project, and users can edit the project information, as shown in Figure 3-24.



Energy Storage Integrated Energy Management System

Project Name: 飞思储能站 | Production Date: 2024-06-13

Configuration Number: 3DC7F3369D5A63 | Grid Connection Date: 2024-06-13

Address: 广西柳州

Plant Type: 独立储能 | Grid-connected/Off-grid Type: 并网

Rated Power: 125 kW | Installed Capacity: 261 kWh

Number of PCS: 1 | Number of Battery Clusters: 1

Grid Connection Voltage Level: 0.4 kV | Load Access Method: Load Power Meter

[Edit](#)

Figure 3- 24 Power Station Information

3.1.13. Meter reading

Manage and view meter and meter reading information, and perform meter reading configuration and meter reading operations, as shown in Figure 3-25.



Energy Storage Integrated Energy Management System

Energy Storage Meter Name: Please enter energy storage | Status: Please select status | [Query](#)


Meter Name	Meter Reading Type	Last Execution Time	Last Execution Result	Next Execution Time	Start Date	End Date	Freezing Capability	Enable Status	Operation
Energy meter	Daily Freeze...	2026-02-11 1...	Failed	2026-02-26 0...	2025-07-15	2999-12-31	With Freezing...	●	Meter Reading Configuration Execute Once Operation Details Delete
Anti-countercur...	--	--	--	--	--	--	--	--	Meter Reading Configuration
Anti-countercur...	--	--	--	--	--	--	--	--	Meter Reading Configuration

Total 3 | 20/page | [Go to 1](#)

Figure 3- 25 Meter Reading

3.1.14. Meter data

Check the meter reading information frozen for 15 minutes and daily freezing of the device, support re-metering and new meter reading data as shown in Figure 3-26.



The screenshot displays the 'Energy Storage Integrated Energy Management System' interface. On the left is a sidebar menu with options like Power Station Overview, PCS, BMS, Battery Cell, Auxiliary Control, Alarm Analysis, Alarm Config, Electrovalence Control, Data Analysis, Operation Strategy, Device Management, Meter Reading Configuration, Electricity Meter Function, **Meter Data**, and System Settings. The main area shows a 'Query' section with a date range of 2026-02-11 18:45:00 to 2026-02-11 17:00:00. Below this is a table of meter reading data.

Meter Reading Time	Forward Active					Reverse Active					Operation
	Total Energy	pointed	peak	Flat	valley	Total Energy	pointed	peak	Flat	valley	
2026-02-11 18:45:00	21099	9	137	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 18:30:00	21099	9	137	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 18:15:00	21099	9	137	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 18:00:00	21099	9	137	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 17:45:00	21099	9	137	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 17:30:00	21099	9	136	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 17:15:00	21098	9	136	1306	19525	18114	285	10335	7285	53	Edit Delete
2026-02-11 17:00:00	21098	9	136	1306	19525	18114	285	10335	7285	53	Edit Delete

Figure 3- 26 Meter Reading Data

The Energy Management Unit (EMU) is an innovative technology with significant advantages, designed specifically for energy storage and microgrid scenarios. It is professionally designed to meet the energy management needs of these systems, integrating network ports, CAN, 485,232, and DI/DO interfaces. This setup fully supports data acquisition and control for BMS, PCS, diesel generators, and photovoltaic inverters. Additionally, the software integrates standard acquisition protocols and supports interfaces from major equipment manufacturers, making it widely applicable in industrial and commercial energy storage, household storage, and microgrid control scenarios.

3.2. Data acquisition function

3.2.1. Home page

On the home page, the network architecture diagram is generated according to the configured collection configuration, and it can also be switched to the display of the list. At the same time, the list form can search for the corresponding device information in the search bar according to your needs. As shown in Figure 4-1 and Figure 4-2.





Figure 4- 1 Network Architecture Diagram



The Device List table provides a comprehensive overview of the connected devices. It includes fields for Device Name, Device Model, Collection Interface, Communication Address, Communication Status, Last Communication Time, Total Communication Times, Successful Communication Times, and Operation. The table lists several devices, including EMU equipment, Cloud Sky PCS, Invic air conditioner, The meter in the cabinet of Ankerui, Youdan BMS, and Meter reading equipment.

Device Name	Device Model	Collection Interface	Communication Address	Communication Status	Last Communication Time	Total Communication Times	Successful Communication Times	Operation
EMU equipment	EMU model	Network port 1	emuSystem TelemetryEVI	Online	2026-02-26 16:51:26	812139	812139	View Variables
Cloud Sky PCS	Cloud Sky PCS	485 serial port 6	1	Online	2026-02-26 16:51:33	381628	381622	View Variables
Invic air conditioner	Invic air conditioner	485 serial port 3	1	Online	2026-02-26 16:51:31	668043	668043	View Variables
The meter in the cabinet of Ankerui	The meter in the cabinet of Ankerui	485 serial port 2	1	Online	2026-02-26 16:51:33	749130	749065	View Variables
Youdan BMS	Youdan BMSV2	can1	1	Online	2026-02-26 16:51:33	107787092	107787092	View Variables
Meter reading equipment	Meter reading model	Network port 1	1	Online	2026-02-26 16:51:10	1	1	View Variables

Figure 4- 2 Device List

3.2.2. Southbound configuration

A functional module for data communication between the gateway and the actual device.

3.2.2.1. Device configuration

The module is divided into three interfaces, namely the interface of all devices, the interface of serial port devices and the interface of network port devices. Click the middle device button to switch, as shown in the figure below. ttyS0~ttyS4 are serial port devices, and network port one and network port two are network port devices.

3.2.2.2. All Device

This interface displays all the configured device interfaces and divides all devices into devices connected to serial ports, as shown in Figure 4-3:




Figure 4- 3 All Device

3.2.2.2.1. Serial port device

Click on the serial port in ttyS0~ttyS4 to display the information of the device connected to the serial port, as shown in Figure 4-4.




Figure 4- 4 Serial Port Device

3.2.2.2. Network port device

Click port 1 and port 2 to display the information of the corresponding devices connected to port 1 and port 2. As shown in Figure 4-5:




Figure 4- 5 Network Port Device

3.2.3. Model configuration

The model configuration is a module used to configure the device point information, including general, PLC, DL/T645-2007, and Modbus models, and the user can add variable parameters to realize the data point configuration through the configuration command information, as shown in Figure 4-6:




Figure 4- 6 Model Configuration

3.2.3.1. Variable details

In the model configuration interface, click the variable details button of the model list to enter the corresponding model variable details interface, which is used to configure the corresponding model point data. As shown in Figure 4-7.




Figure 4-7 Variable Details

3.2.4. Operation configuration

Run the configuration, formulate device collection rules, such as the collection cycle and the number of offline judgments, and then bind the devices defined by the device configuration module, and one running configuration can be bound to multiple devices. As shown in Figure 4-8:




Figure 4-8 Operation Configuration

3.2.4.1. Debug

The interface can debug the devices bound to the current running configuration, such as command issuance, manual collection, stop collection and message debugging, as shown in Figure 4-9:





Figure 4- 9 Debug

Function:

- 1) The command is issued: the pop-up window shows the writable points, and the command can be issued.
- 2) Manual collection: manual collection once.
- 3) Stop collection: Click stop collection to temporarily stop the collection according to the cycle configured by the operation configuration. Exit the page or click again to resume the cycle collection.
- 4) Click on the right , the system log information of the current device will appear.

3.2.5. Subroutine configuration

The management and configuration of each subroutine running in the system allows users to view, add, edit and delete subroutines, as well as configure the operating parameters of the subroutines. As shown in Figure 4 -10:




Subprogram Name	Process Name	Execution Command	Working Directory	Auto Start	Auto Restart	Operation
can_tcp	can_tcp_linux_arm64	/root/gwai/protocolChannel/can_tcp/can_tcp_linux_arm64	/root/gwai/protocolChannel/can_tcp/	☒	☒	View Edit Delete
dt645	dt645_linux_arm64	/root/gwai/protocolChannel/dt645/dt645_linux_arm64	/root/gwai/protocolChannel/dt645/	☒	☒	View Edit Delete
can_bus	can_bus_linux_arm64	/root/gwai/protocolChannel/can_bus/can_bus_linux_arm64	/root/gwai/protocolChannel/can_bus/	☒	☒	View Edit Delete
modbus-tcp	modbus_tcp_linux_arm64	/root/gwai/protocolChannel/modbus_tcp/modbus_tcp_linux_arm64	/root/gwai/protocolChannel/modbus_tcp	☒	☒	View Edit Delete
modbus-rtu	modbus_rtu_linux_arm64	/root/gwai/protocolChannel/modbus_rtu/modbus_rtu_linux_arm64	/root/gwai/protocolChannel/modbus_rtu	☒	☒	View Edit Delete

Figure 4- 10 Subroutine Configuration

3.2.6. Northbound configuration

3.2.6.1. Reporting channel

Through the configuration of the reporting channel, the collected data is reported to the specified platform. As shown in Figure 4-11:



Service Name	Protocol Name	Specify Reporting Channel	Reporting Network Card	Reporting Address	Reporting Port	Reporting Period (seconds)	Heartbeat	Switch	Online Status	Operation
Feisjy_iot	FSJY.MQTT	Yes		47.119.159.68	1883	180	60	☒	Online	Reporting Node Edit Delete
DIWEN1	Dwin.Serial	Yes				180	-	☒	Online	Reporting Node Edit Delete
From the plan e report	ModbusTCP	No	-		10080	-	5	☒	Online	Reporting Node Edit Delete
abx_iot	FSJY.MQTT	No	-	ess.51xch.cn	21883	180	60	☒	Online	Reporting Node Edit Delete

Figure 4- 11 Reporting Channel

3.2.6.2. Report nodes

Report the device information corresponding to the channel, as shown in Figure 4-12:




Figure 4- 12 Report Nodes

3.2.7. Alarm rules

3.2.7.1. Alarm configuration

By adding the rule to configure the point rule of the device, it can judge whether the point data collected conforms to the rule and generate an alarm record. As shown in Figure 4-13:




Figure 4-13 Alarm Configuration

3.2.7.2. Alarm history

After the rules are configured, the generation time and other information of the rules will be recorded every time the rules are started. After the rules are triggered, alarm events can be manually processed. As shown in Figure 4-14:

飞思捷

ESUNTECH

Figure 4- 14 Alarm History

3.2.8. Configuration management

3.2.8.1. Configuration list

The configuration list is used to display the overview of the power station, PCS, BMS and other pages. Users can configure the required related pages through the configuration, and can intuitively observe the running status of the current equipment through the configuration. As shown in Figure 4-15:

长恩科技

DEPLENT

🏠

Home

📁

Collection C...

▼

📁

Reporting C...

▼

📁

Control Stra...

▼

📁

Alert Rules

▼

📁

Configuratio...

▲

📄

Configuration List

📁

Image Management

📁

System Con...

▼

📁

System Man...

▼

📁

System Deb...

▼

📁

Rule Engine

▼

☰

Collapse Sidebar

Energy Management Control Unit (EMU) | v5.0.0 | Uptime: 0

CPU

3.76%

Memory

26.22%

Disk

67.07%

📶

0%

📶

0%

👤

...

Configuration Name

Please enter the configuratio

Search

Add

Code	Name	Description	Operation				
3E535EE9A1EA01	pcs		Copy	Modify	Edit	Run	Delete
3E535EED5A5425	Home		Copy	Modify	Edit	Run	Delete
3E53792399B168	bms		Copy	Modify	Edit	Run	Delete
3E59C0E8745FA0	bms(copy)		Copy	Modify	Edit	Run	Delete

Total 4

10/page

<

1

>

Go to

1

Figure 4- 15 Configuration Management

3.2.8.2. Image management

Image management is the place for configuration picture management. It contains many configuration pictures, classifies and organizes them, and provides an interface for uploading pictures. As shown in Figure 4-16:




Figure 4-16 Image Management

3.2.9. System configuration

3.2.9.1. Storage Settings

Configure the parameters related to data storage in the system, including reported data storage and historical storage. As shown in Figure 4-17:




Figure 4- 17 Storage Settings

3.2.9.2. NTP calibration

The configuration and management system synchronizes the time function automatically calibrates the system time through the Network Time Protocol (NTP) server. As shown in Figure 4-18:




Figure 4- 18 NTP Calibration

3.2.9.3. Dictionary management

Maintain various data dictionaries used in the system, and users can view, add, modify and delete dictionary entries to ensure the standardization and consistency of system data. As shown in Figure 4-19:




Figure 4-19 Dictionary Management

3.2.10. System management

3.2.10.1. User management

It includes adding, querying, editing and deleting users, as well as resetting user passwords for users in the management system. As shown in Figure 4-20:




Figure 4- 20 User Management

3.2.10.2. Character management

The roles in the management system include adding, querying, editing and deleting roles, as well as updating user status and configuring menus. As shown in Figure 4-21:





Figure 4- 21 Character Management

3.2.10.3. Menu management

The menu used in the management system includes adding, querying, editing and deleting menus, as well as sorting menus and other operations. As shown in Figure 4-22:




Menu Name	Sort	Permission Identifier	Creation Time	Operation
Data Acquisition Gateway	-	-	-	Add
Home	-	-	-	Modify Delete
Acquisition configuration	1	-	-	Modify Add Delete
Report the configuration	2	-	-	Modify Add Delete
Control strategy	4	-	-	Modify Add Delete
Alarm rules	5	-	-	Modify Add Delete
Configuration management	6	-	-	Modify Add Delete
Configuration list	-	-	-	Modify Delete
Image management	1	-	-	Modify Delete
System configuration	7	-	-	Modify Add Delete

Figure 4- 22 Menu Management

3.2.10.4. Log management

Log management records important information such as the IP address and time of user login to the platform, tracks and audits user operation behaviors, and ensures the security and compliance of the platform. As shown in Figure 4-23:



Login Name	User	Ip	Content	Time
root	Super admin	113.13.116.46	Log in to the collection platform	2026-02-26 09:57:00
root	Super admin	113.13.116.163	Log in to the collection platform	2026-02-09 10:47:50
root	Super admin	113.13.116.163	Log in to the collection platform	2026-02-06 17:33:07
root	Super admin	119.123.184.60	Log in to the collection platform	2026-02-06 09:55:46
root	Super admin	119.123.184.60	Log in to the collection platform	2026-02-05 08:44:58
root	Super admin	113.13.116.163	Log in to the collection platform	2026-02-04 17:18:37
root	Super admin	119.123.184.60	Log in to the collection platform	2026-02-04 17:05:30
root	Super admin	113.13.116.163	Log in to the collection platform	2026-02-04 17:04:41
root	Super admin	113.13.117.168	Log in to the collection platform	2026-01-23 19:39:15
root	Super admin	113.13.117.168	Log in to the collection platform	2026-01-22 10:04:10

Figure 4- 23 Log Management

3.2.11. System debugging

3.2.11.1. Channel debugging

By opening serial port, CAN port, TCP client and other methods, the debugging channel is ensured to be smooth, and the accuracy of the data sent by the message is verified. As shown in Figure 4-24:




Figure 4- 24 Channel Debugging

3.2.11.2. System logs

View and analyze the log information generated during the operation of the system to understand the running status of the system and troubleshoot errors. As shown in Figure 4-25:




Figure 4- 25 System Logs

3.2.11.3. System monitoring

System monitoring is used to monitor the performance indicators of the system in real time to ensure the stability and reliability of the system. As shown in Figure 4-26:




Figure 4- 26 System Monitoring

3.2.12. Rule engine

3.2.12.1. Rule configuration

Rules are configured to manage and configure rules. Users can create new rules, set the trigger conditions and actions of the rules, and view, edit, and delete configured rules. As shown in Figure 4-27:





Figure 4- 27 Rule Configuration

4. EMU Hardware Requirements

The EMU Energy Management Monitoring Controller is an innovative technology with significant advantages, designed specifically for energy storage and microgrid applications. Compared to traditional devices like 4G routers, 5G routers, and PLC controllers, the EMU offers integrated management, simplifies system architecture, reduces the number of devices, and lowers maintenance costs. It also provides efficient energy management through real-time monitoring and intelligent control, optimizing energy storage and utilization. The controller can precisely manage energy storage devices and offer flexible energy dispatch strategies to enhance system stability and reliability, improve energy efficiency. Whether for industrial, commercial, or residential users, the EMU Energy Management Monitoring Controller offers convenience and benefits, making it an ideal solution for energy storage systems. It features a high-end ARM processor, including a quad-core ARM Cortex-A35 and an integrated GPU and NPU. The controller boasts high efficiency, performance, and cost-effectiveness, supporting 512MB memory and 32G onboard storage. The gateway integrates various functional interfaces, including Ethernet, 4G, 5G, WiFi, RS485, RS232, HDMI, and DI/DO.


4.1. Product features

EMU monitors the equipment for energy storage and energy management scenarios in an all-round way, can timely collect the real-time operating status of PCS/BMS/auxiliary control equipment, and supports IO control output.



It is suitable for small and medium-sized energy storage scenarios and can be used as a multi-cabinet cabinet

4.2. Product view



Front panel size: 230 long, 43.80 high, 200 wide;

4.3. EMU parameter

4.3.1. Hardware parameters


Device	Detailed description
CPU	ARM core platform, quad-core ARM Cortex-A35@1.3G Hz frequency
RAM	512MB DDR3
storage	32GB eMMC, can support expansion mSATA interface hard disk, up to 1TB;
4G	1 road 4G interface, support ordinary SIM card
Ethernet port	4 road 100M RJ45 network ports, including 2 ring network ports
Serial	10 road, including 8 road 485 serial ports, 2 road 232 serial ports, with isolation;
CAN	2 road CAN2.0
DI	10 road, 10 dry contact inputs
DO	8 road, normally open, 30VDC/5A
USB	1 supports USB2.0 HOST, which can be used for touch screen, USB flash drive, mouse, and keyboard, etc
Watch Dogs	CPU built-in watchdog
Debug/OTG	2 TypeC interfaces
Electric Source	DC 24V (Wide Pressure 9V-36V)
Overall Machine Size	230x167x43.8mm
Heat Dissipation Method	Passive heat dissipation, no fan
Working Environment	-30°C~+55°C

4.4. Screen optional

Product features:

- Based on T5L2 chip, running DGUS II system, commercial grade.
- 10.1 inches, 1024*600 resolution, 16.7M color, IPS screen, wide viewing angle.
- Resistive touch screen.
- With a case.

Screen interface diagram:






Hardware and interface description:

No.	Name	Description
1	T5L2 chip T5L2 ASIC	Mass product in 2019, 1MBytes on-chip Nor Flash , of which 512KBytes are used to store user databases,Erase times>100,000 times
2	LCM interface	FPC50_0.5mm, RGB interface
3	RTP interface	4Pin_1.0mm interface
4	User interface	12KByte/s 8Pin_3.81mm socket for power supply and serial communication. Download rate(typical value): 12KByte/s
5	Flash	16MBytes NOR Flash, for fonts, pictures and audio files. Rewrite cycle: over 100,000 times
6	Expand Flash interface	Expandable to 64Mbytes NOR Flash or 48Mbytes NOR Flash+512Mbytes NAND Flash
7	Buzzer	3V passive buzzer. Power: <1W
8	RTC	Button cell for power supply. Accuracy: $\pm 20\text{ppm}@25^{\circ}\text{C}$
9	SD interface	FAT32. Download files by SD interface can be displayed in statistics
10	Reserved module interface	Wi-Fi module: connect to the cloud platform to update remotely USB module: download files by USB flash disk
11	PGT05 interface	When product crashes by accident, you can use PGT05 to update DGUS kernel and make the product return to normal

Packaging and physical dimensions:

Form Factor	264.1mm (W)×178.0mm (H) ×21.0mm (T)			
Net Weight	660g			
Packaging Standards				
packaging box model	Dimensions	Layer	Quantity/Layer	Quantity(Pcs)
Carton1:	220mm(L)×160mm(W)×47mm (H)	-	-	-
Carton2:	250mm(L)×200mm(W)×80mm (H)	-	-	-
Carton3:	320mm(L)×270mm(W)×80mm (H)	-	-	-
Carton4:	435mm(L)×335mm(W)×290mm(H)	-	-	-
Carton5:	600mm(L)×430mm(W)×290mm(H)	1	10	10





Make energy storage safer and more efficient

Make Energy Storage Safer and More Efficient

Shenzhen Feisi Jieyue Technology Co., Ltd.

<https://www.feisjy.com>

Email: support@feisjy.com